

**E-CHALLAN (Manual Payment)**  
**Government Of Rajasthan**  
**Public Health Engineering Department**

Valid Upto:- 31/03/2024 Remitter's Copy

GRN :- **76385414** Date:- 30/05/2023 3:07:00 PM

BarCode:- 

Office Name:- **Junior Chemist PHED Jhunjhunu**

Location:- **JHUNJHUNU**

Year: 30/05/2023 To 31/05/2023

Head(0215)	Amount	₹
------------	--------	---

0215-02-800-01-00-MISC. RECEIPT	400.00	
---------------------------------	--------	--

Discount :- ₹ 0.00

Total/Net Amount:- ₹ 400.00

Four Hundred Rupees and Zero Paise Only

**Payee Detail**

TIN/Actt. no./VehicleNo/Taxid/Lease No:- JPRJ06793D

PAN No.:-

Remitter Name:- **JUNIOR CHEMIST PHED LABORATORY  
JHUNJHUNU**


Address:- Junior Chemist PHED Lab Jhunjhunu Jhunjhunu-333001


Remarks: Water testing Fees received from Central Children Academy Jakhar Farm House Indali Road Khatehpura Jhunjhunu

**FOR USE IN RECEIVING BANK**

Cheque-DD-No.:

Bank CIN No.:

Bank  SBI AnyWhere

30 MAY 2023  




**PUBLIC HEALTH ENGINEERING DEPARTMENT  
LABORATORY JHUNJHUNU**

**CHEMICAL EXAMINATION REPORT OF WATER**

No. Lab. / Chem. /2023-24/ 164

Date - 30.5.2023

To,  
The Principal  
Central Children Academy  
Jakhar Farm House, Indali Road  
Khatehpura  
Ref- Yours letter dated 26-5-2023


Distt:- Jhunjhunu

Tehsil:-Jhunjhunu

Date of Exam -30-05-2023

A	Name & Location of Source			Water Sample Central Children Academy
B	Village/ Town			Khatehpura
C	Date Of Collection			30-5-2023
D	Lab. Sample No.			C-14
Sr. No	Parameters	Desirable limits	Permissible limits	Analysed Value
1	pH	6.5—8.5	6.5—8.5	7.4
2	Turbidity[NTU]	1	5	Nil
3	Temperature[C]	-----	-----	25
4	Colour[Units]	5 Hazen Unit	15 Hazen Unit	None
5	Odour	Unobjectionable	Unobjectionable	Unobj.
6	Total Alkalinity[asCaCO <sub>3</sub> ]	200	600	130
7	Total Hardness[asCaCO <sub>3</sub> ]	200	600	90
8	Calcium [asCa]	75	200	20
9	Magnesium [as Mg]	30	100	9.6
10	Chloride[asCl <sup>-1</sup> ]	250	1000	70
11	Nitrate[as NO <sub>3</sub> <sup>-1</sup> ]	45	45	05
12	Fluoride [as F <sup>-1</sup> ]	1.0	1.5	0.2
13	TDS	500	2000	306

Note: All Results Except pH in mg/L.

  
(S K Sharma)  
Junior Chemist  
PHED Laboratory Jhunjhunu

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY  
CONDITION  
CERTIFICATE.**

No. 164

Date : 30.5.2023

It is certified that an inspection team headed by Surendra Kumar Sharma  
Junior chemist

(Name of  
Officers

with designation) from DHEG Laboratory, Jhunjhunu. (Name

of Department/Office) inspected the CENTRAL CHILDREN ACADEMY - JAKHAR  
FARM HOUSE INDALI ROAD KHATEHPURA JHUNJHUNU (Name & Address

of the School) on \_\_\_\_\_ and found that the CENTRAL CHILDREN ACADEMY  
JAKHAR FARM HOUSE INDALI ROAD KHATEHPURA (Name of school) has  
safe drinking water facilities for the students and members of staff of the institution and is  
maintaining the hygienic sanitation condition in the school building & the campus as per the  
norms prescribed by the Central/State/U.T Govt.

The above valid for a period of One year.

Signature with Seal :

(सुरेन्द्र कुमार शर्मा)  
कनिष्ठ रसायनज्ञ

Name :

जन स्वा० अभि० विभाग

Designation :

प्रयोगशाला, झुंझुनूं

To

PRINCIPAL

CENTRAL CHILDREN ACADEMY

JAKHAR FARM HOUSE INDALI ROAD KHATEHPURA JHUNJHUNU.

(Name & Address of the Institution)